



July 5, 2004

Greg Kats, Chairman  
Energy & Atmosphere TAG  
USGBC LEED 3.0  
gkats@aiaa.com

Dear Mr. Kats:

I am writing you to urge a revision in a section of the LEED standard relating to selection of refrigerants in HVAC and refrigeration equipment.

The current version of LEED 2.0 and current drafts of the proposed revision 3.0 provide an energy credit for elimination of HCFCs as well as halons. While the intent here to support early elimination of ozone-depleting substances may appear laudatory, the actual effect could be counter-productive from an overall environmental perspective. As Green Seal determined in the development of its Environmental Standard for Electric Chillers, GS-31, the complete elimination of HCFCs with today's HVAC equipment may lead to a significant loss of energy efficiency, and consequently a significant increase in the amount of global warming emissions for which the HVAC system is responsible. This is a result of the high energy efficiency of HCFC-123 compared to other refrigerants, including non-ozone-depleting ones, as well as its low GWP in the event of leakage. Moreover, HCFC-123 has an ODP of only 0.02, when combined with strict controls on leakage, the ozone-depleting impact of HCFC-123 can be minimized.

In crafting its chiller standard, Green Seal recognized these trade-offs and sought a balance by requiring both low ODP (less than or equal to 0.02) and high energy efficiency. In addition, the standard requires that annual system leakage during routine operation not exceed 1%. We believe these requirements would more effectively achieve the intent of LEED both to reduce ozone depletion and to abate global warming emissions and other adverse impacts of energy use. Consequently, we respectfully request that the relevant language for Energy Credit 4 be replaced by the following:

*Install base building level HVAC and refrigeration equipment in accordance with Green Seal Environmental Standard GS-31, where applicable. Refrigeration equipment must use CFC, HCFC, or ammonia refrigerants with an ODP less than 0.02, and the refrigerant fill with a positive ODP must result in energy efficiency greater than that of global ODP alternatives.*

Green Seal • 100 Connecticut Ave

The use of our environmental standards in LEED is a prerequisite in EQ Credit 4, which references the Green Seal form standard for its VOC and ingredient criteria. Our standards, including GS-31, may be obtained on our Web site at [www.greenseal.org](http://www.greenseal.org).

Additional background on this issue and the essentials in addressing it are provided below. If you have any questions about this matter, please feel free to speak with Mark Betts, Director of Certification at tel: (202) 832-6460 x23 or [mpb@greenseal.org](mailto:mpb@greenseal.org).

Thank you very much for your attention to this matter.

Sincerely,  
  
Arthur B. Weisgram, Ph.D.  
President and CEO  
Green Seal

cc: Bill Reed