

LEED 2.0 (current)

ENERGY CREDIT 4:	Elimination of HCFC's and Halons
INTENT:	Reduce ozone depletion and support early compliance with the Montreal Protocol.
REQUIREMENT:	Install base building level HVAC and refrigeration equipment and fire suppression systems that do not contain HCFC's or Halon.

LEED 3.0 Draft Proposal

ENERGY CREDIT 4:	<u>Reduction of Ozone-Depleting and Global Warming Substances</u>
INTENT:	Reduce ozone depletion and global warming potential and support compliance with the Montreal Protocol <u>and the Framework Convention on Climate Change.</u>
REQUIREMENT:	Install base building level HVAC and refrigeration equipment <u>certified in accordance with Green Seal standard GS-31 where applicable.</u> <u>Otherwise, equipment which has a positive ODP must result in efficiencies greater than that of other non-ODP alternatives</u> and <u>must be suitable for commercial air-conditioning use under EPA's Significant New Alternatives Program (SNAP).</u> The fire suppression systems shall contain no Halons.