



Intent

To achieve increasing levels of energy conservation beyond the referenced standard to reduce environmental and economic impacts associated with excessive energy use.

Requirements

MANDATORY POINT MINIMUM: Project registered on or after [April 8, 2016](#) must earn four points in this credit, but can come from any of the four sub-sections.

Reduce connected lighting power density below that allowed by ANSI/ASHRAE/IESNA Standard 90.1-2007 (with errata but without addenda¹) using either the space-by-space method or by applying the whole building lighting power allowance to the entire tenant space.

The points earned for reducing lighting power density below the standard are as follows:

Lighting Power Density Reduction below the Standard	Points
15%	1
20%	2
25%	3
30%	4
35%	5

Project teams in California may use Title 24-2005, Part 6 in place of ANSI/ASHRAE/IESNA Standard 90.1-2007.