



LEED BD+C: Schools | v3 - LEED 2009

## Minimum indoor air quality performance

EQp1 | Required

Glossary

### Intent

To establish minimum indoor air quality (IAQ) performance to enhance indoor air quality in buildings, thus contributing to the comfort and well-being of the occupants.

### Requirements

#### Case 1. Mechanically ventilated spaces

Mechanical ventilation systems must be designed using the ventilation rate procedure as defined by ASHRAE 62.1-2007, or the applicable local code, whichever is more stringent.

#### Option 1. ASHRAE standard 62.1-2007 or non-U.S. equivalent

Meet the minimum requirements of Sections 4 through 7 of ASHRAE Standard 62.1-2007, Ventilation for Acceptable Indoor Air Quality (with errata but without addenda<sup>1</sup>). Projects outside the U.S. may use a local equivalent to Sections 4 through 7 of ASHRAE Standard 62.1-2007.

#### OR

#### Option 2. CEN standards EN 15251: 2007 and EN 13779: 2007

Projects outside the U.S. may earn this prerequisite by meeting the minimum requirements of Annex B of Comité Européen de Normalisation (CEN) Standard EN 15251: 2007, Indoor environmental input parameters for design and assessment of energy performance of buildings addressing indoor air quality, thermal environment, lighting and acoustics; and the requirements of CEN Standard EN 13779: 2007, Ventilation for nonresidential buildings, Performance requirements for ventilation and room conditioning systems, excluding Section 7.3 - Thermal environment, 7.6 - Acoustic Environment, A.16, and A.17.

#### OR

#### Case 2. Naturally ventilated spaces

Naturally ventilated buildings must comply with ASHRAE Standard 62.1-2007, Paragraph 5.1 (with errata but without addenda<sup>1</sup>).

#### Credit substitution available

You may use the LEED v4 version of this credit on v2009 projects. For more information [check out this article](#).