



LEED ID+C: Retail | v3 - LEED 2009

Construction IAQ management plan - during construction

EQc3.1 | Possible 1 point

Glossary

Intent

To reduce indoor air quality (IAQ) problems resulting from construction or renovation and promote the comfort and well-being of construction workers and building occupants.

Requirements

Develop and implement an IAQ management plan for the construction and preoccupancy phases of the building as follows:

- During construction, meet or exceed the recommended control measures of the Sheet Metal and Air Conditioning National Contractors Association (SMACNA) IAQ Guidelines For Occupied Buildings Under Construction, 2nd Edition 2007, ANSI/SMACNA 008-2008 (Chapter 3).
- Protect stored on-site and installed absorptive materials from moisture damage.
- If permanently installed air handlers are used during construction, filtration media must be used at each return air grille that meets one of the following criteria below. Replace all filtration media immediately prior to occupancy.
 - Filtration media with a minimum efficiency reporting value (MERV) of 8 as determined by ASHRAE Standard 52.2-1999 (with errata but without addenda¹)
 - Filtration media is Class F5 or higher, as defined by CEN Standard EN 779-2002, Particulate air filters for general ventilation, Determination of the filtration performance
 - [\[East Asia ACP: Construction IAQ Equivalent\]](#)
 - Filtration media with a minimum dust spot efficiency of 30% or higher and greater than 90% arrestance on a particle size of 3-10 µg

Alternative Compliance Paths (ACPs)

East Asia ACP: Construction IAQ Equivalent

Projects in East Asia may use filtration media classified as medium efficiency (□□□□) or higher as defined by Chinese standard GB/T 14295-2008□□□□□□.



[LEED 2009 Retail reference guide supplement with East Asia ACPs](#)