



| v2 - LEED 2.2

Innovative wastewater technologies

WEC2 | Possible 1 point

Glossary

Intent

Reduce the generation of wastewater and potable water demand, while increasing the local aquifer recharge.

Requirements

Option 1

Reduce potable water use for building sewage conveyance by 50% through the use of water-conserving fixtures (water closets, urinals) or non-potable water (captured rainwater, recycled greywater, and on-site or municipally treated wastewater).

OR

Option 2

Treat 50% of wastewater on-site to tertiary standards. Treated water must be infiltrated or used on-site.