



| v3 - LEED 2008

Heat island reduction - non-roof

SSc7.1 | Possible 1 point

Glossary

Intent

Reduce heat islands (thermal gradient differences between developed and undeveloped areas) to minimize impact on microclimate and human and wildlife habitat.

Requirements

Choose one of the following options:

Option A

Use any combination of the following strategies for 50% of the site hardscape (including roads, sidewalks, courtyards and parking lots):

- Provide shade from existing tree canopy or within five years of landscape installation; landscaping (trees) must be in place at the time of certification application.
- Provide shade from structures fully covered by solar photovoltaic panels.
- Provide shade from architectural devices or structures that have a solar reflectance index (SRI) of at least 29. Implement a maintenance program that ensures these surfaces are cleaned at least every two years to maintain good reflectance.
- Have paving materials with an SRI of at least 29 and implement a maintenance program that ensures these surfaces are cleaned at least every two years to maintain good reflectance.
- Have an open-grid pavement system (at least 50% pervious).

Option B

Place a minimum of 50% of parking spaces under cover (defined as underground, under deck, under roof or under a building). Any roof used to shade or cover parking must have an SRI of at least 29. Implement a maintenance program that ensures all SRI surfaces are cleaned at least every two years to maintain good reflectance. The top parking level of a multilevel parking structure is included in the total parking spaces calculation but is not considered a roof and is not required to be an SRI surface.