



| v2 - LEED 2.0

## CFC reduction in HVAC/R equipment

EAp3 | Required

Glossary

### Intent

Reduce ozone depletion.

### Requirements

Zero use of CFC-based refrigerants in tenant HVAC&R systems when within scope of work.