



## Measurement and verification

EAC5 | Possible 1 point

### Intent

Provide for the ongoing accountability of building energy consumption over time.

### Requirements

- Develop and implement a Measurement & Verification (M&V) Plan consistent with Option D: Calibrated Simulation (Savings Estimation Method 2), or Option B: Energy Conservation Measure Isolation, as specified in the *International Performance Measurement & Verification Protocol (IPMVP) Volume III: Concepts and Options for Determining Energy Savings in New Construction, April, 2003*.
- The M&V period shall cover a period of no less than one year of post-construction occupancy.
- Provide a process for corrective action to ensure energy savings are realized if the results of the M & V plan indicate that energy savings are not being achieved.