

## Mold prevention

EQc10 | Possible 1 point

### Intent

Reduce the potential presence of mold in schools through preventive design and construction measures.

### Requirements

Project teams must achieve the following credits:

1. EQ Credit 3.1: Construction IAQ management plan: during construction
2. EQ Credit 7.1: Thermal comfort: compliance
3. EQ Credit 7.2: Thermal comfort: verification

### **AND**

Provide HVAC systems and controls designed to limit space relative humidity to 60% or less during all load conditions, both occupied and unoccupied.

### **AND**

Develop and implement on an ongoing basis an IAQ management program for buildings based on the EPA document "Building Air Quality: A Guide for Building Owners and Facility Managers," EPA Reference Number 402-F-91-102, December 1991.