



| v2 - LEED 2.0

## Fundamental refrigerant management

EAp3 | Required

Glossary

### Intent

Reduce ozone depletion.

### Requirements

Zero use of CFC-based refrigerants in new base building HVAC&R systems. When reusing existing base building HVAC equipment, complete a comprehensive CFC phase-out conversion prior to project completion. Phase-out plans extending beyond the project completion date will be considered on their merits. Small HVAC units (defined as containing less than 0.5 lbs of refrigerant), and other equipment such as standard refrigerators, small water coolers, and any other cooling equipment that contains less than 0.5 lbs of refrigerant, are not considered part of the "base building" system and are not subject to the requirements of this credit.