



### Intent

Limit disruption of natural water flows by eliminating stormwater runoff, increasing on-site infiltration and eliminating contaminants.

### Requirements

Construct site stormwater treatment systems designed to remove 80% of the average annual post-development total suspended solids (TSS) and 40% of the average annual post-development total phosphorous (TP) based on the average annual loadings from all storms less than or equal to the 2-year/24-hour storm. Do so by implementing Best Management Practices (BMPs) outlined in Chapter 4, Part 2 (Urban Runoff), of the United States Environmental Protection Agency's (EPA's) *Guidance Specifying Management Measures for Sources of Nonpoint Pollution in Coastal Waters*, January 1993 (Document No. EPA 840B92002) or the local government's BMP document (whichever is more stringent).