



| v2 - LEED 2.1

Light pollution reduction

SSc8 | Possible 1 point

Glossary

Intent

Eliminate light trespass from the building and site, improve night sky access and reduce development impact on nocturnal environments.

Requirements

Meet or provide lower light levels and uniformity ratios than those recommended by the Illuminating Engineering Society of North America (IESNA) *Recommended Practice Manual: Lighting for Exterior Environments* (RP-33-99). Design exterior lighting such that all exterior luminaires with more than 1000 initial lamp lumens are shielded and all luminaires with more than 3500 initial lamp lumens meet the Full Cutoff IESNA Classification. The maximum candela value of all interior lighting shall fall within the building (not out through windows) and the maximum candela value of all exterior lighting shall fall within the property. Any luminaire within a distance of 2.5 times its mounting height from the property boundary shall have shielding such that no light from that luminaire crosses the property boundary.