



## CFC reduction in HVAC/R equipment

EAp3 | Required

### Intent

Reduce ozone depletion.

### Requirements

Zero use of CFC-based refrigerants in new base building HVAC&R systems. When reusing existing base building HVAC equipment, complete a comprehensive CFC phase-out conversion.