



## Controllability of systems - perimeter spaces

EQc6.1 | Possible 1 point

### Intent

Provide a high level of thermal, ventilation and lighting system control by individual occupants or specific groups in multi-occupant spaces (i.e. classrooms or conference areas) to promote the productivity, comfort and well-being of building occupants.

### Requirements

Provide at least an average of one operable window and one lighting control zone per 200 square feet for all regularly occupied areas within 15 feet of the perimeter wall.