



# Indoor water use reduction

Required

## Intent

To reduce indoor water consumption.

## Requirements

### Building Water Use

For the fixtures and fittings listed in Table 1, as applicable to the project scope, reduce aggregate water consumption by 20% from the baseline. Base calculations on the volumes and flow rates shown in Table 1.

All newly installed toilets, urinals, private lavatory faucets, and showerheads that are eligible for labeling must be WaterSense labeled (or a local equivalent for projects outside the U.S.).

**Table 1. Baseline water consumption of fixtures and fittings**

Commercial Fixtures, Fittings, and Appliances	Current Baseline (IP Units)	Current Baseline (SI units)
Water closets (toilets)*	1.6 gallons per flush (gpf)	6 liters per flush (lpf)
Urinal*	1.0 (gpf)	3.8 lpf
Public lavatory (restroom) faucet	0.5 gpm at 60 psi all others except private applications	1.9 lpm at 415 kPa, all others except private applications
Private lavatory faucet*	2.2 gpm at 60 psi	8.3 lpm at 415 kPa
Kitchen faucet (excluding faucets used exclusively for filling operations)	2.2 gpm at 60 psi	8.3 lpm at 415 kPa
Showerhead*	2.5 gpm at 80 psi per shower stall	9.5 lpm at 550 kPa per shower stall

\* WaterSense label available for this product type  
gpf = gallons per flush  
gpm = gallons per minute  
psi = pounds per square inch  
lpf = liters per flush  
lpm = liters per minute  
kPa = kilopascals

### Appliance and process water use

Install appliances, equipment, and processes within the project scope that meet the requirements listed in the tables below .

**Table 2. Standards for appliances**

Appliance	Requirement
Residential clothes washers	ENERGY STAR or performance equivalent
Commercial clothes washers	CEE Tier 3A
Residential dishwashers (standard and compact)	ENERGY STAR or performance equivalent
Prerinse spray valves	≤ 1.3 gpm (4.9 lpm)
Ice machine	ENERGY STAR or performance equivalent and use either air-cooled or closed-loop cooling, such as chilled or condenser water system

gpm = gallons per minute

lpm = liters per minute

**Table 3. Standards for processes**

Process	Requirement
Heat rejection and cooling	No once-through cooling with potable water for any equipment or appliances that reject heat
Cooling towers and evaporative condensers	Equip with: <ul style="list-style-type: none"> <li>▫ makeup water meters</li> <li>▫ conductivity controllers and overflow alarms</li> <li>▫ efficient drift eliminators that reduce drift to maximum of 0.002% of recirculated water volume for counterflow</li> </ul>

Efficient eliminators that reduce dirt to maximum of 0.002% of recirculated water volume for counterflow towers and 0.005% of recirculated water flow for cross-flow towers