



## Water use reduction

WEc3.1-3.2 | Possible 2 points

### Intent

Maximize water efficiency within buildings to reduce the burden on municipal water supply and wastewater systems.

### Requirements

**Credit 3.1** (1 point) Employ strategies that in aggregate use 20% less water than the water use baseline calculated for the building (not including irrigation) after meeting Energy Policy Act of 1992 fixture performance requirements.

**Credit 3.2** (1 point) Exceed the potable water use reduction by an additional 10% (30% total efficiency increase).