



| v2 - LEED 2.0

CFC reduction in HVAC/R equipment

EAp3 | Required

Glossary

Intent

Reduce ozone depletion.

Requirements

Zero use of CFC-based refrigerants in new building HVAC&R base building systems. When reusing existing base building HVAC equipment, complete a comprehensive CFC phaseout conversion.