



## Controllability of systems - non-perimeter spaces

EQC6.2 | Possible 1 point

### Intent

Provide a high level of individual occupant control of thermal, ventilation, and lighting systems to support optimum health, productivity, and comfort conditions.

### Requirements

Provide controls for each individual for airflow, temperature and lighting for at least 50% of the occupants in non-perimeter, regularly occupied areas.