



| v2 - LEED 2.0

Controllability of systems - non-perimeter spaces

EQC6.2 | Possible 1 point

Glossary

Intent

Provide a high level of individual occupant control of thermal, ventilation, and lighting systems to support optimum health, productivity, and comfort conditions.

Requirements

Provide controls for each individual for airflow, temperature and lighting for at least 50% of the occupants in non-perimeter, regularly occupied areas.