



| v4 - LEED v4

Minimum indoor air quality performance

Required

Glossary

Requirements

Meet the requirements for both ventilation and monitoring.

Ventilation

Mechanically ventilated spaces

For mechanically ventilated spaces (and for mixed-mode systems when the mechanical ventilation is activated), choose one of the following cases.

Case 1. Systems able to meet required outdoor airflow rates

Option 1. ASHRAE Standard 62.1-2010

Determine the minimum outdoor air intake flow for mechanical ventilation systems using the ventilation rate procedure from ASHRAE 62.1-2010 or a local equivalent, whichever is more stringent and meet the minimum requirements of ASHRAE Standard 62.1-2010, Sections 4-7, Ventilation for Acceptable Indoor Air Quality (with errata), or a local equivalent, whichever is more stringent.

Option 2. CEN Standards EN 15251-2007 and EN 13779-2007

Projects outside the U.S. may instead meet the minimum outdoor air requirements of Annex B of Comité Européen de Normalisation (CEN) Standard EN 15251-2007, Indoor environmental input parameters for design and assessment of energy performance of buildings addressing indoor air quality, thermal environment, lighting and acoustics; and meet the requirements of CEN Standard EN 13779-2007, Ventilation for nonresidential buildings, Performance requirements for ventilation and room conditioning systems, excluding Section 7.3, Thermal environment; 7.6, Acoustic environment; A.16; and A.17.

Case 2. Systems unable to meet required outdoor airflow rates

If meeting the outdoor airflow rates in Case 1 is not feasible because of the physical constraints of the existing ventilation system, complete an engineering assessment of the system's maximum outdoor air delivery rate. Supply the maximum possible to reach the minimum setpoint in Case 1 and not less than 10 cubic feet per minute (5 liters per second) of outdoor air per person.

Naturally ventilated spaces

For naturally ventilated spaces (and for mixed-mode systems when the mechanical ventilation is inactivated), determine the minimum outdoor air opening and space configuration requirements using the natural ventilation procedure from ASHRAE Standard 62.1-2010 or a local equivalent, whichever is more stringent. Confirm that natural ventilation is an effective strategy for the project by following the flow diagram in the Chartered Institution of Building Services Engineers (CIBSE) Applications Manual AM10, March 2005, Natural Ventilation in Nondomestic Buildings, Figure 2.8 and meet the requirements of ASHRAE Standard 62.1-2010, Section 4, or a local equivalent, whichever is more stringent.

All spaces

The indoor air quality procedure defined in ASHRAE Standard 62.1-2010 may not be used to comply with this prerequisite.

Monitoring

Mechanically ventilated spaces

For mechanically ventilated spaces (and for mixed-mode systems when the mechanical ventilation is activated), monitor outdoor air intake flow as follows:

- For variable air volume systems with an outdoor air intake in the project scope of work, provide a direct outdoor airflow measurement device capable of measuring the minimum outdoor air intake flow with an accuracy of +/-10% of the design minimum outdoor airflow rate, as defined by the ventilation requirements above. An alarm must indicate when the outdoor airflow value varies by 15% or more from the outdoor airflow setpoint.
- For constant-volume systems included in the project scope of work, balance outdoor airflow to the design minimum outdoor airflow rate defined by ASHRAE Standard 62.1-2010 (with errata), or higher. Install a current transducer on the supply fan, an airflow switch, or similar monitoring device.

Naturally ventilated spaces

For naturally ventilated spaces (and for mixed-mode systems when the mechanical ventilation is inactivated), comply with at least one of the following.

- Provide a direct exhaust airflow measurement device capable of measuring the exhaust airflow with an accuracy of +/-10% of the design minimum exhaust airflow rate. An alarm must indicate when airflow values vary by 15% or more from the exhaust airflow setpoint.
- Provide automatic indication devices on all natural ventilation openings intended to meet the minimum opening requirements. An alarm must indicate when any one of the openings is closed during occupied hours.
- Monitor carbon dioxide (CO₂) concentrations within each thermal zone. CO₂ monitors must be between 3 and 6 feet (900 and 1 800 millimeters) above the floor and within the thermal zone. CO₂ monitors must have an audible or visual indicator or alert the building automation system if the sensed CO₂ concentration exceeds the setpoint by more than 10%. Calculate appropriate CO₂

