



| v1 - LEED 1.0 pilot

CFC reduction in HVAC&R equipment

EAp3 | Required

Glossary

Intent

Reduce ozone depletion.

Requirements

Zero use of CFC-based refrigerants in tenant HVAC&R systems when within the scope of work.

Small HVAC units (defined as containing less than 0.5 lbs of refrigerant), and other equipment such as standard refrigerators, small water coolers, and any other cooling equipment that contains less than 0.5 lbs of refrigerant, are not considered part of the "base building" system and are not subject to the requirements of this credit.