USGBC.org - Scheduled Maintenance
From **Friday, May 15, 8:00 PM to Monday, May 18, 8:00 AM EST**, USGBC.org will be offline for site maintenance.
Email us or call 1-800-795-1747 for assistance. Thanks for your patience.

LEED BD+C: Core and Shell | v3 - LEED 2009

Innovation: Cooling Tower Water Management

EBOM v3 WEc4.1 | Possible 1 point

Glossary

Intent

To reduce potable water consumption for cooling tower or evaporative condenser equipment through effective water management and/or use of nonpotable makeup water.

Requirements

WE credit 4.1 (1 point): Chemical management

Develop and implement a water management plan for the cooling tower or evaporative condenser that addresses chemical treatment, bleed-off, biological control and staff training as it relates to cooling tower maintenance.

Improve water efficiency by installing and/or maintaining a conductivity meter and automatic controls to adjust the bleed rate and maintain proper concentration at all times.

Address
2101 L Street NW
Suite 500
Washington, DC 20037

Within the United States:
1-800-795-1747

Outside the United States:
1-202-742-3792

© 2012-2015 U.S. Green Building Council