



### Intent

To reduce wastewater generation and potable water demand while increasing the local aquifer recharge.

### Requirements

#### **OPTION 1 (1 point):**

Treat 100% of wastewater on-site to tertiary standards. Treated water must be used on-site

AND/OR

#### **OPTION 2 (1 point):**

Use treated wastewater or captured rain water, to reduce potable water consumption for air- conditioning make-up by 50% (if the project uses water-cooled chillers); **(AND)** Reduce potable water use for building sewage conveyance by 50% through the use of non-potable water (e.g., treated wastewater, municipally treated wastewater, captured rainwater).