

[Please upgrade your browser](#). This site requires a newer version to work correctly. [Read more](#)
Our "watch" feature allows you to stay current on all aspects of this specific credit. In your account, you can control what you get updated on and how you receive your notifications. [Hide](#)

LEED ND: Plan | v4 - LEED v4

Wastewater management

Possible 2 points

1 result in All .

Intent

To reduce pollution from [wastewater](#) and encourage water [reuse](#).

Requirements

Design and construct the project to retain on-site at least 25% of the average annual [wastewater](#) generated by the project (excluding any existing buildings), and [reuse](#) that wastewater to replace [potable water](#). Provide on-site treatment to a quality required by state and local regulations for the proposed reuse, whichever is more stringent. Calculate the percentage of wastewater diverted and reused by determining the total wastewater flow, using the design case from GIB Prerequisite Indoor Water Use Reduction and adding wastewater flow from residential buildings, then determining how much of that volume is reused on site.

Table 1. Points for reusing wastewater

Percentage of wastewater reused	Points
25%	1
50%	2