

Please upgrade your browser. This site requires a newer version to work correctly. [Read more](#)



Our "watch" feature allows you to stay current on all aspects of this specific credit. In your account, you can control what you get updated on and how you receive your notifications. [Hide](#)

LEED O+M: Existing Buildings | v4 - LEED v4

Indoor air quality management program

Possible 2 points

1 result in All .

Intent

To maintain the well-being of occupants by preventing and correcting indoor air quality problems.

Requirements

Establishment

Develop and implement an indoor air quality (IAQ) management program based on the EPA Indoor Air Quality Building Education and Assessment Model (I-BEAM). Include the IAQ management program in the project's current facilities requirements and operations and maintenance plan. .

Performance

Conduct an I-BEAM audit on a regular basis (at least once every five years) and revise the IAQ management program as appropriate.