



INFORMATION

Note: This document contains addenda information that is supplemental to that found in the LEED Interpretations and Addenda database, found on <http://www.usgbc.org>.

Addendum Details:

Addenda Number	Post Date	Rating System	Category	Credit ID	Ref Guide	Issue Type	Page	Location	Supplemental Document
100000753	02/02/2011		Water Efficiency	WEp1: Water Use Reduction	BD+C, 2009	Non-grammatical	171	Table 2	Tables

ISSUE: Replace the table with the two tables below.

Supplemental Document:

Tables				
Table 2a. Non-residential Default Fixture Uses, by Occupancy Type				
Fixture Type	Duration (sec)	Uses / Day		
		FTE	Transient (Student / Visitor)	Retail Customer
Water Closet (Female)	n/a	3	0.5	0.2
Water Closet (Male)	n/a	1	0.1	0.1
Urinal (Female)	n/a	0	0	0
Urinal (Male)	n/a	2	0.4	0.1
Lavatory Faucet *	30*	3	0.5	0.2
Shower	300	0.1	0	0
Kitchen Sink	15	1	0	0

* Default duration for the metering type / autocontrol faucet is 15 seconds for the baseline and 12 seconds for the design case.

Table 2b. Residential Default Fixture Uses

Fixture Type	Duration (sec)	Uses / Day
Water Closet (Female)	n/a	5
Water Closet (Male)	n/a	5
Lavatory Faucet	60	5
Shower	480	1
Kitchen Sink	60	4